

Emergency Eyewash/Shower Inspection Checklist

General Requirements	Yes	No	N/A	Comments
1. Is the eye wash/shower within 40 feet and a max of 10 seconds from exposure?				
2. Is there proper signage?				
3. Is the area well lit?				
4. Is the area and the path to the eyewash/shower blocked or hidden?				
5. Are there items stacked on the eyewash?				
6. Are dust caps/covers in place over spray nozzles?				
7. Has the unit been damaged or is water leaking from the unit?				
8. Is there any dirt or dust on the unit? If so, clean the unit from dirt and debris.				
9. Is the pull cord (shower) and the hand/foot pedal operational?				
10. Is the unit operational? Both eyewash and shower.				
11. Can the eyewash station deliver hands-free, constant water flow for 15 minutes?				
12. Can the unit be activated within 1 second or less with a hand or foot?				
13. Is there adequate water pressure and flow?				
14. Do the protective caps or covers come off the spray nozzles once the unit has been initiated?				
15. Does the company have an emergency action plan and first-aid procedures in place?				

Inspector: _____

Date: _____

KEMI does not assume liability for the content of information contained herein. Safety and health remain your responsibility. This information is to be used for informational purposes only and not intended to be exhaustive or a substitute for proper training, supervision or manufacturers' instructions/recommendations. KEMI, by publication of this information, does not assume liability for damage or injury arising from reliance upon it. Compliance with this information is not a guarantee or warranty that you will be in conformity with any laws or regulations nor does it ensure the absolute safety of any person, place or object, including, but not limited to, you, your occupation, employees, customers or place of business.